

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHIECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, Troja, 182 00 Praha 8

CERTIFICATE

No.: 1240487

Product: Insulating rods with holders

Type: IZT - V, IZT - J (see Annex)

Rating: long 500 mm (see Annex)

Ordering firm: KOVOBLESK KPS OPAVA s.r.o.
Radkov 15, 747 83 Radkov, Czech Republic

Manufacturer: KOVOBLESK KPS OPAVA s.r.o.
Radkov 15, 747 83 Radkov, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 242342-01/01 of: 10.10.2024

A sample of the product was found to be in conformity with:
ČSN EN 62561-4 ed. 2:2018 cl. 4, 5.5, 6.3.4, 6.4.1, 6.4.2, 6.4.3, 6.5, 6.7

Other data:

The validity of the certificate is limited to: 15.10.2027

16.10.2024

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



242342-01

Separate insulating rod: IZT

Version	Length (L-mm)
GFK	1000

Insulating rod for wire mounting with a metal head ($\varnothing$ 8,10 mm): IZT - V

Version	Length (L-mm)
FeZn/GFK	500
	750
	1000

Insulating rod for air termination rod mounting with a metal head: IZT - J

Version	Length (L-mm)
FeZn/GFK	500
	750
	1000

Structural elements for insulating rods for fixing to a protected building:

- holder OH into the masonry of the object - straight
- holder OH into the masonry of the object - straight - perpendicular
- holder OH into the masonry of the object - straight - parallel
- holder OH on the corner of the object
- holder OH into the masonry with a screw
- holder OH into the masonry with a nail
- holder OH for air termination rod
- holder OH on the pipe
- holder OH on a pylon universal (ST UNI- stainless steel tape)

