

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHIECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, Troja, 182 00 Praha 8

CERTIFICATE

No.: 1240356

Product: Telescopic air termination rod

Type: JTK (see Annex)

Rating: variants 5 m up to 10 m

Ordering firm: KOVOBLESK KPS OPAVA s.r.o.
Radkov 15, 747 83 Radkov, Czech Republic

Manufacturer: KOVOBLESK KPS OPAVA s.r.o.
Radkov 15, 747 83 Radkov, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 240429-01/01 of: 23.07.2024

A sample of the product was found to be in conformity with:
ČSN EN IEC 62561-2 ed. 2:2018 cl. 4.3, 5.2.5, 5.2.6

Other data:

The validity of the certificate is limited to: 29.07.2027

30.07.2024

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



240429-01

Chart of standard air-termination assemblies: 5 m to 10 m

Type marking	Lengths of part for the air-termination assembly (m)				Set weight approx. (kg)
	Tube Ø 40x4	Tube Ø 32x3,5	Tube Ø 25x5	Rod Ø 16/10	
JTK 50	2	1	1	1/0	136
JTK 60	3	1	1	1/0	139
JTK 70	3	1	1	1/1	140
JTK 80	4	1	1	1/1	202
JTK 90	4	2	1	1/1	203
JTK 100	3	3	2	1/1	208

